

NOTES:

WATERMAIN 8" OR LARGER

1. VALVE BOX COVER SHALL BE SET 1/4" BELOW FINAL GRADE OF ASPHALT/CONCRETE PAVEMENT.
2. VALVE BOXES PLACED IN AREAS OTHER THAN PAVEMENT (I.E. DIRT OR LANDSCAPING) SHALL HAVE A 18"SQX6" THICK REINFORCED CONCRETE COLLAR SET FLUSH WITH FINAL GRADE. CONCRETE PAD TO BE PLACED USING PROPER FORMS; SET SQUARE AND FLUSH WITH GROUND.
3. IF THE DISTANCE FROM FINAL GRADE TO THE OPERATING NUT IS GREATER THAN 6'-6", OPERATOR EXTENSIONS SHALL BE CONNECTED TO VALVE OPERATOR USING SET SCREW TO RAISE THE NUT TO WITHIN 12" BELOW GRADE.
4. TYLER 6860 SERIES BOX WITH WIDE OVAL BASE, OR APPROVED EQUAL, REQUIRED ON ALL VALVES INCLUDING ALL CURB STOPS EXCEPT 3/4" RESIDENTIAL SERVICES.
5. FOR FIRE HYDRANT VALVE, LID READS "FIRE". FOR OTHER UTILITIES VALVE BOX LID SHALL READ "SEWER", "IRRIGATION", ETC. RESPECTIVE TO THE TYPE OF SERVICE.
6. DO NOT RUN TRACER WIRE UP VALVE BOXES.